

Weekly Water Report	As of: Nov. 21, 2022	As of: Dec. 5, 2022	
New Hogan (NHG) TOC	174,100	152,100	AF
Storage:	49,891	50,592	AF
Net Storage Change:	-566	+701	AF
Inflow:	24	181	CFS
Release:	63	26	CFS
New Melones (NML) Allocation		75,000	AF
Storage:	586,912	590,733	AF
Net Storage change:	+1,497	+3,821	AF
Inflow:	213	760	CFS
Release:	50	258	CFS
Source: CDEC Daily Reports			

Goodwin Diversion (GDW)			
Inflow (Tulloch Dam):	46	277	CFS
Release to Stanislaus River (S-98):	202	209	CFS
Release to OID (JT Main):	0	0	CFS
Release to SSJID (SO Main):	0	0	CFS
Release to SEWD:	<u>0</u>	<u>0</u>	CFS
Total Release	202	209	CFS
Source: Tri-Dam Operations Daily Report			
Farmington Dam (FRM)			
Diverted to SEWD:	N/A	N/A	CFS
Diverted to CSJWCD:	0	0	CFS
Source: USACE WCDS Hourly Report			

Surface Water Used			
Irrigators on New Hogan:	0	0	
Irrigators on New Melones:	0	0	
Out-Of-District Irrigators:	0	0	
DJWWTP Production:	26	24	MGD
North Stockton:	0	0	MGD
South Stockton:	4	4	MGD
Cal Water:	20	21	MGD
City of Stockton DWSP Production:	12.7	10.8	MGD

District Ground Water Extraction			
74-01	884	883	GPM
74-02	528	523	GPM
North	516	503	GPM
South	1,798	1,756	GPM
Extraction Well # 1	<u>3,140</u>	<u>3,130</u>	GPM
Total Well Water Extraction	6,866	6,795	GPM
Total Ground Water Production	9.9	9.8	MGD

Note: All flow data reported here is preliminary and subject to revision.